

- NOTE 1: FIELD WIRING AND CONTAINMENT BY OTHERS
- NOTE 2: IF EMERGENCY RETRACT IS REQUIRED ALL FIELD WIRING MUST BE FP200 OR EQUIVALENT
- CONTROL UNITS TO BE ACCESSIBLE SHOULD THERE BE A TOTAL LOSS OF POWER TO ENABLE RESETTING OF THE SYSTEM NOTE 3:

	Edward House, Penner Road,	drawn: RW	TYPICAL WIRING DIAGRAM MK4-S MONO	
coopers	Havant, Hampshire, PO9 1QZ, UK Tel: +44 (0) 23 9245 4405 Fax: +44 (0) 23 9249 2732	CHECKED: JR	© 1997-2016 A COOPER GROUP LIMITED ALL RIGHTS RESERVED. THIS DESIGN MAY NOT BE REPRODUCED IN ANY MATERIAL FORM, INCLUDING ELECTRONICALLY WITHOUT THE WRITTEN PERMISSION OF THE COPYRIGHT NAMES	ALL DIMENSION IN MILLIMETERS UNLESS OTHERWISE STATED
•	Email: info@coopersfire.com	APPROVED:	DRG. No.	ISSUE: A
Coopers Fire Limited	Web: www.coopersfire.com	JR	MK4-S	DATE: 05/07/16

3 CORE + E 1.5MM FP200 FLYING LEAD BY COOPERS

3 CORE + E EXTENSION CABLE

1.5MM = 25MM MAX

