

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-FA7002

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

SmokeStop[®] Concertina[™]

Intended use: Smoke barrier for smoke control in construction works in industrial and commercial locations

Essential characteristics	Level or Class	Technical specification
Operational Reliability	Pass	EN 12101-1: 2005+ A1: 2006, Clause 5.3
Response Delay	Pass	EN 12101-1: 2005+ A1: 2006, Clause 5.4
Deployment Safety	Pass	EN 12101-1: 2005+ A1: 2006, Clause 5.4
Fire Resistance - Smoke Leakage	Pass	EN 12101-1: 2005+ A1: 2006, Clause 5.5.5
Fire Resistance - Mechanical Stability	DH60 / D60	EN 12101-1: 2005+ A1: 2006, Clause 5.2
Fire Resistance - Integrity	DH60 / D60	EN 12101-1: 2005+ A1: 2006, Clause 5.2

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-FA7002

Placed on the market under the name of

**Coopers Fire Ltd
Ignis House
Houghton Avenue
Waterlooville
Hampshire
PO7 3DU
United Kingdom**

and produced in the manufacturing plant.

E/355

This is coded format, and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 12101-1: 2005 + A1: 2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **24/03/2023** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **23/03/2026**



0087



Paul Duggan
Certification Manager

**Warringtonfire Testing and Certification Limited
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK**