

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-FA5002

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### SmokeStop® Concertina™

**Intended use: Smoke barrier for smoke control in construction works in industrial and commercial locations**

Essential characteristics	Level or Class	Technical specification
Operational Reliability	Pass	EN 12101-1:2005/A1:2006, Clause 5.3
Response Delay	Pass	EN 12101-1:2005/A1:2006, Clause 5.4
Deployment Safety	Pass	EN 12101-1:2005/A1:2006, Clause 5.4
Fire Resistance - Smoke Leakage	Pass	EN 12101-1:2005/A1:2006, Clause 5.5.5
Fire Resistance - Mechanical Stability	DH60 / D60	EN 12101-1:2005/A1:2006, Clause 5.2
Fire Resistance - Integrity	DH60 / D60	EN 12101-1:2005/A1:2006, Clause 5.2

## Certificate of Constancy of Performance

**2812-CPR-FA5002**

Placed on the Market under the Name of:

**Coopers Fire Ltd  
Ignis House  
Houghton Avenue  
Waterlooville  
Hampshire  
PO7 3DU  
United Kingdom**

and produced in the manufacturing plant

**E/355**

**This is coded format and the information is held by the Notified Body**

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard:

**EN 12101-1:2005/A1:2006**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **24/09/2020** and revised on **15/11/2023** and will remain valid until the below date, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **14/11/2026**

ERO Project Reference: **ERO 034621 P2210**



Pascal Coget  
General Manager  
European Certification

CSF408-NL 8.0