



---

## CERTIFICATE OF APPROVAL

### No CF 5794

---

This is to certify that, in accordance with  
TS00 General Requirements for Certification of Fire Protection Products  
The undermentioned products of

## COOPERS FIRE LTD

Ignis House, Houghton Avenue, Waterlooville, Hampshire,  
PO7 3DU, United Kingdom

Phone 02392 454405

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---

#### CERTIFIED PRODUCT

SmokeStop® Active Smoke  
Barrier Overlapping or Single  
Barrel System (A1 Fabric)

#### TECHNICAL SCHEDULE

TS 30 – Industrial Type Fire  
Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan  
Certification Manager



Issued: 29<sup>th</sup> October 2019  
Reissued: 13<sup>th</sup> May 2024  
Valid to: 9<sup>th</sup> November 2025





---

## CERTIFICATE No CF 5794

### COOPERS FIRE LTD

---

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the performance of active smoke barriers, manufactured by Coopers Fire Ltd. The barriers are certificated against the following performance requirements of EN 12101-1: 2006, at an unlimited width (subject to constructional requirements) (incorporating the use of barrel support brackets as defined in the Constructional Specification) and maximum height (inc. headbox) of 4840mm:  
  
Annex D - Temperature time (DH120 Classification).  
Annex C - Smoke permeability (leakage rate not exceeding 25 m<sup>3</sup> per hour per m<sup>2</sup>).  
Annex B - Reliability/Response/Durability (pass).
3. The aforementioned barriers are also separately certificated against the essential requirements of Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR) under Certificate of Constancy of Performance referenced 2812-CPR-FA5013.
4. The product is CERTIFIRE approved on the basis of:
  - i) Initial type testing.
  - ii) An appraisal against TS30.
  - iii) Inspection and surveillance of factory production control
  - iv) Audit testing
5. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Signed Page 2 of 2  
CIH10133-1

Issued: 29<sup>th</sup> October 2019  
Reissued: 13<sup>th</sup> May 2024  
Valid to: 9<sup>th</sup> November 2025