



---

## CERTIFICATE OF APPROVAL

### No CF 10091

---

This is to certify that, in accordance with  
TS00 General Requirements for Certification of Fire Protection Products  
The undermentioned products of

## COOPERS FIRE LTD

**Ignis House, Houghton Avenue, Waterlooville, Hampshire,  
PO7 3DU, United Kingdom  
Tel: 02392 454405**

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---

#### CERTIFIED PRODUCT

**FireMaster® Insul8 – 90 Active  
Fire Curtain**

#### TECHNICAL SCHEDULE

**TS 30 – Industrial Type Fire  
Resisting Doorsets**

**Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited**

**Paul Duggan  
Certification Manager**

**Issued:  
Reissued:  
Valid to:**

**21<sup>st</sup> February 2024  
8<sup>th</sup> May 2024  
20<sup>th</sup> February 2029**





---

## CERTIFICATE No CF 10091

### COOPERS FIRE LTD

---

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the use of FireMaster® Insul8 – 90 Active Fire Curtain in providing a fire resistance performance of up to 90 minutes integrity and insulation, up to 240 minutes integrity only or up to 240 minutes integrity and radiation, as defined in BS EN 1634-1: 2014 + A1: 2018. This certificate is restricted to fire exposure from one direction only - the curtain shall be mounted onto the opposite side of the wall to the known direction of fire exposure. The scope of approval is summarised as follows:

#### **Continuous Barriers / Single Roller**

Rating	Maximum Height (mm)	Maximum Width (mm)
Up to 90 minutes integrity and insulation	2640	7000
Up to 240 minutes integrity only	2640	7000
Up to 240 minutes integrity and radiation	2640	7000

All dimensions quoted in the above table are internally between guides and from underside of head box to floor level (i.e. visible fabric dimensions).

3. The product is CERTIFIRE approved on the basis of:
  - i) Initial type testing,
  - ii) An appraisal against the requirements of TS30,
  - iii) Inspection and surveillance of the Factory Production Control,
  - iv) Audit testing at a frequency as defined within TS30.
4. The approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
5. The FireMaster® Insul8 – 90 Active Fire Curtains are approved for installation on to the unexposed face of a concrete or masonry supporting construction having a fire resistance performance no less than that required for the fire curtain (see paragraph No.2, above, in regards limitation on direction of exposure). Typical installation details are provided in the datasheet.

Signed Page 2 of 2  
CIH10133-1

Issued: 21<sup>st</sup> February 2024  
Reissued: 8<sup>th</sup> May 2024  
Valid to: 20<sup>th</sup> February 2029